

AIR FILTRATION
& AIR QUALITY



HEPALAM-69-ARK

Laminar Flow Absolute Filters

FILTER CODE STRUCTURE

Type	HL	HEPALAM-69
Class EN 1822	12	99,9 @0.3 µm
Frame	A	A: Aluminum
Media	R	R: Micro Glass Fibre S: Synthetic Y: High Heat
Pleat Depth	K	S: 0.55-1inch K: 1-1.88 inch
Surface Grid	2	0: Without Grid 1: Face Grid Air Outlet 2: Both Side with Grid
Gasket Type	P	X: Without Gasket P: Polyurethane R: Rubber E: Epdm Y: High Heat
Gasket Direction	G	X: No C: Air Outlet G: Air Inlet W: Both Side
Size		24-24-3

APPLICATIONS

To be used for absolute air filtration in controlled contamination environments clean rooms, LAF benches and operating rooms

TECHNICAL SPECIFICATIONS

Efficiency @0.3 µm	95 %	99 %	99,9 %	99.99 %	99.999 %	99.9999 %
Max. Temperature	176 °F (Optional 248 °F)					
Relative Humidity	100 %					
Rec. Final Pres. Drop	2.4 w.g.					
Filter Stage	III - IV					

For more information please click here. 

