

AIR FILTRATION
& AIR QUALITY



HEPALAM-78-ARM

Laminar Flow Absolute Filters

APPLICATIONS

To be used for absolute air filtration in controlled contamination environments clean rooms, LAF benches and operating rooms

FILTER CODE STRUCTURE

Type	HL	HEPALAM-78
Class EN1822	11	%95 @0.3 µm
Frame	A	A: Aluminum
Media	R	R: Micro Glass Fibre S: Synthetic Y: High Heat
Pleat Depth	M	S: 0.55-1inch K: 1-1.88 inch M: 1.9-2.28 inch
Surface Grid	2	0: Without Grid 1: Face Grid Air Outlet 2: Both Side with Grid
Gasket Type	P	X: Without Gasket P: Polyurethane R: Rubber E: Epdm Y: High Heat
Gasket Direction	G	X: No C: Air Outlet G: Air Inlet W: Both Side
Size	24-24-3	

TECHNICAL SPECIFICATIONS

Efficiency @0.3 µm	95 %	99 %	99,9 %	99.99 %	99.999 %	99.9999 %
Max. Temperature	176 °F (Optional 248 °F)					
Relative Humidity	100 %					
Rec. Final Pres. Drop	2.4w.g.					
Filter Stage	III - IV					

For more information please click here.

